

Minnesota Geothermal Heat Pump Association 2012

Properly Sizing Ground Source Heat Pump Systems




Richard Hiles
ClimateMaster

Objective


**Properly Size and Select
GSHP System for Low Operating
Costs And Proper Control of
Indoor Air Conditions**



Solar Energy is Absorbed by the Earth



Heat Is Transferred Through an Earth Loop



- Plastic pipe is buried in the earth around the building
- When liquid is pumped through the pipe, it transfers energy with the earth around it
- Insulating layer of earth
- 40-70°F

Sizing Procedures

Calculate Building / Zone Heating / Cooling Loads

Select Geothermal Heat Pump/s for Building / Zones

Design Ground Loop System Using a Software Program

Run Operating Costs Comparison Using a Software Program

Verify Dehumidification in Cooling Mode

Check Effects on Ground Loop System by Unit Size

Objectives: Building Loads Residential

Heating and cooling loads are required for each zone / area that will have a ground loop system

Residential - Manual "J" load Calculation

Room by Room loads for duct sizing & CFM

Total Zone or Building loads for Equipment Selection

Cooling Load MUST Include Sensible and Latent Loads

Objectives: Building Loads Residential

Various Software Programs to Calculate Loads

**Input Data
Outside
Walls**

1		Room name		Entire House		First Floor			
2		Exposed wall		200.0 ft.		200.0 ft.			
3		Room dimensions				40.0 x 60.0 ft.			
4		Ceiling height		8.0		8.0 heat/cool			
Type of exposure		CST	H-HTM	C-HTM	Area	H-BtuH	C-BtuH		
5		Gross Exposed Walls and Partitions		a 12H b c d e f	1600		1600		
					0		0		
					0		0		
					0		0		
					0		0		
					0		0		
					0		0		
6		Windows and Glass Doors Heating		a 3C b c d e f	180	6917	180	6917	
					0	0	0	0	
					0	0	0	0	
					0	0	0	0	
					0	0	0	0	
					0	0	0	0	
					0	0	0	0	
7		Windows and Glass Doors Cooling		North	21.4	50	1079	50	1079
				NE and NW	0.0	0	0	0	0
				East and West	65.5	90	5895	90	5895
				SE and SW	0.0	0	0	0	0
				South	34.9	40	1382	40	1382
				Horizontal	0.0	0	0	0	0

Objectives: Building Loads Residential

Windows Cooling

Select Type

Direction

Shading
CLG HTM

Zone / room: Entire House / First Floor

Glazing CST: 3C (Metal Frame, Dbl Pane, Clear Glass)

Glazing orientation:

s	e	n	w
45.0	45.0	45.0	45.0

Glazing area (sqft):

a	a	a	a
c	c	c	c

Wall / ceiling type (see F5):

a	a	a	a
n	n	n	n

Glazing type (c, h, r):

c	c	c	c
n	n	n	n

Storms on in summer (y, n):

90	90	90	90
n	n	n	n

Inclination angle (0 - 90):

0.90	0.90	0.90	0.90
n	n	n	n

Shading type (n, d, b, s, i):

1.00	1.00	1.00	1.00
2.00	2.00	2.00	2.00

Shading coefficient (.01 - 1.0):

5.00	5.00	5.00	5.00
5.00	5.00	5.00	5.00

Overhang depth, A (ft):

1.00	1.00	1.00	1.00
2.00	2.00	2.00	2.00

Overhang to glazing distance, B (ft):


2.00	2.00	2.00	2.00
5.00	5.00	5.00	5.00

Glazing height, C (ft):

5.00	5.00	5.00	5.00
5.00	5.00	5.00	5.00

Component cooling HTM:

[34.9]	[65.5]	[21.4]	[65.5]
5.00	5.00	5.00	5.00



Note: Any overhang-shaded portion will be entered on the worksheet as facing north.

Objectives: Building Loads Residential

Doors, Ceiling, Floors & Infiltration

**Input
Doors**

6	Other Doors		a 11B [19.5] [7.2] 48 934 345 48 934 345	b 10C [19.1] [7.1] 48 916 339 48 916 339								
9	Net Exposed Walls and Partitions		a 12H 3.2 1.2 1324 4210 1557 1324 4210 1557	b 0.0 0.0 0 0 0 0 0 0 0	c 0.0 0.0 0 0 0 0 0 0 0	d 0.0 0.0 0 0 0 0 0 0 0	e 0.0 0.0 0 0 0 0 0 0 0	f 0.0 0.0 0 0 0 0 0 0 0				
10	Ceilings		a 16G [1.7] [1.3] 2400 4198 3168 2400 4198 3168	b [0.0] [0.0] 0 0 0 0 0 0	c [0.0] [0.0] 0 0 0 0 0 0							
11	Floors		a 19F [5.8] [0.0] 2400 13865 0 2400 13865	b [0.0] [0.0] 0 0 0 0 0 0	c [0.0] [0.0] 0 0 0 0 0 0							
12	Infiltration			61.0 8.2 276 16824	2257 276 16824 2257							

**Input
Floors**

Infiltration

Objectives: Building Loads Residential

Loads Subtotals

HTG

**Internal
Gains**

**CLG
CFM**

13 14 15	Subtotal Btuh Loss=6+8+9+10+11+12 Duct Btuh Loss Total Btuh Loss = 13+14	47863 4786 52649	10 %	47863 4786 52649	10 %	47863 4786 52649
16 17 18	Internal Gains: People @ 300 Appliances @ 1200 Subtotal RSH Gain=7+8+9+10+11+12+16 Duct Btuh Gain	2 2 600 2400 19022 951	2 2 5 %	2 2 19022 951	2 2 5 %	600 2400 19022 951
15 19 20	Total Btuh Loss = 13+14 Total RSH Gain = (17+18)*PLF CFM air required	52649 19973 956	1.00	52649 19973 956	1.00	52649 19973 956


Objectives: Building Loads Residential

Heating and Cooling Loads Total

**Design
Conditions**

**Heating
Load**

**Cooling
Sensible
Latent
Total**



Objectives: Select Heat Pumps Residential

Units are Normally Selected for Heating Load in Northern Climates

Size Unit by the Dominate Load / Heating or Cooling

Select 2 Stage High Efficiency Geothermal Units

Unit Should Cover Approximately 95% of Annual Heating Requirements

Must Check Sensible and Latent Cooling Capacity

Use Manufacturers Software Program!!

Objectives: Select Heat Pumps Residential

Packaged Units in
Upflow
Downflow
Horizontal
Split Units

Water to Water



2-Stage Copeland UltraTech Compressor




Solenoid
Valve
AC/DC
converter
“unloading”
control

- Same “Footprint” as Single Speed Compressor
- Thicker Shell than R22 Version
- Anti-rotation Device to Insure Quiet Operation
- Solenoid Switches Speed
- R-410A Compressors Have Lower Failure Rates than R22

Copeland UltraTech /Two-Stage Unloading Scroll


With Copeland Scroll UltraTech™, two internal bypass ports enable the system to run at 67% part-load capacity for better efficiency and humidity control. Based on demand, the modulation ring is activated, sealing the bypass ports and instantly shifting capacity to 100%. Take advantage of “shift on the fly” stage changing (no stopping and starting required like other two-stage compressors).

67% Capacity



Gas By-pass - Ports Open

100% Capacity



Ports Closed

Objectives: Select Heat Pumps Commercial

Unit Selected by Dominate Load / Typically Cooling in Commercial Applications

Select Geothermal High Efficiency Units

Unit Net Sensible Cooling Capacity Must Meet or Exceed Sensible Cooling Load - Verify Heating Capacity and Latent Capacity

Dual Capacity Machines are Recommended

Units Rated by ARI standard 13256-1

“Reheat” option for humidity control

Objectives: Select Heat Pumps

ARI/ISO 13256-1 GLHP Ratings are at 77°F

EWT for Cooling and 32°F EWT for Heating

ARI/ASHRAE/ISO 13256-1

English (IP) Units

Model	Capacity Modulation	Water Loop Heat Pump				Ground Water Heat Pump				Ground Loop Heat Pump			
		Cooling Water 86°F		Heating Water 68°F		Cooling Water 59°F		Heating Water 50°F		Cooling Full Load 77°F Part Load 68°F		Heating Full Load 32°F Part Load 41°F	
		Capacity Btuh	EER Btuh/W	Capacity Btuh	COP	Capacity Btuh	EER Btuh/W	Capacity Btuh	COP	Capacity Btuh	EER Btuh/W	Capacity Btuh	COP
TT026	Full	25,300	15.9	30,800	5.3	28,900	24.5	25,700	4.8	26,600	18.5	19,800	4.0
	Part	19,400	18.3	22,400	6.1	22,200	30.8	18,600	5.1	21,200	26.0	16,500	4.6
TT038	Full	36,200	15.6	44,800	5.3	41,200	23.0	36,700	4.7	38,200	18.2	29,000	4.0
	Part	26,200	18.5	30,800	6.3	30,200	31.5	24,800	5.1	28,900	27.0	22,100	4.5
TT049	Full	48,400	15.7	59,900	5.2	54,600	22.5	48,300	4.7	50,600	17.9	37,500	4.0
	Part	36,100	18.0	44,300	6.2	40,700	28.7	35,400	5.1	39,600	24.9	31,200	4.6
TT064	Full	61,500	15.0	72,300	5.0	68,600	22.0	59,600	4.4	64,800	17.5	48,000	3.9
	Part	44,900	17.6	51,100	5.7	51,900	29.7	41,800	4.7	49,800	25.3	37,500	4.3

Cooling capacities based upon 80.6°F DB, 66.2°F WB entering air temperature

Heating capacities based upon 68°F DB, 59°F WB entering air temperature

All ratings based upon 208V operation

Ground loop heat pump ratings based upon 15% antifreeze solution

Certified in accordance with the ARI/ISO Standard 13256-1 Certification Program, which replaced ARI Standard-320, 325, and 330.



Rev: 07/06/04

Objectives: Select Heat Pumps Commercial

Commercial applications may require larger capacity products, rooftop units, console products or vertical stack products.



Objectives: Select Heat Pumps Residential


Units are Rated at AHRI Conditions

Units Need to be Selected at **Maximum**
and Minimum Loop Design Temperatures

Typically 30°F Minimum Entering Water
Temperature (EWT) & 95°F Maximum EWT

Objectives: Select Heat Pumps Residential Water to Water

Radiant Floor Heating Comfort Levels




Objectives: Select Heat Pumps Residential Water to Water




Radiant
Floor
Install

Objectives: Water to Water Typical Installation



Objectives: Water to Water

W to W with W to A Units



Objectives: Select Heat Pumps Residential Water to Water

Equipment Rated at GLHP or GWHP

Load / Heated Water at 86°F EWT & 104°F

Source at 32°F EWT or 50°F EWT

60Hz Units		Ground Loop Heat Pump				Ground Water Heat Pump			
Model		Heating				Heating			
		Indoor 86/95°F, Outdoor 32/27°F*	Indoor 104/113°F, Outdoor 32/27°F*	Indoor 86/95°F, Outdoor 50/45°F*	Indoor 104/113°F, Outdoor 50/45°F*				
		Indoor 30/35°C, Outdoor 0/-3°C*	Indoor 40/45°C, Outdoor 0/-3°C*	Indoor 30/35°C, Outdoor 10/7°C*	Indoor 40/45°C, Outdoor 10/7°C*				
		Capacity Btuh [kW]	COP W/W	Capacity Btuh [kW]	COP W/W	Capacity Btuh [kW]	COP W/W	Capacity Btuh [kW]	COP W/W
	THW010	32.6 [9.57]	4.2	30.8 [9.03]	3.3	42.6 [12.50]	5.2	39.9 [11.69]	4.1

Objectives: Water to Water / 3 Ton

Select Unit by Capacity at System Peak Conditions

30*F EWT Source & 3 GPM / Ton and Leaving Load Temperature & 3 GPM / Ton

SOURCE			LOAD																						
EWT F	Flow		EWT	Flow 4.5 GPM						Flow 6.8 GPM						Flow 9.0 GPM									
	GPM	WPD		HC Mbtuh	Power KW	HE Mbtuh	LWT F	COP	WPD		HC Mbtuh	Power KW	HE Mbtuh	LWT F	COP	WPD		HC Mbtuh	Power KW	HE Mbtuh	LWT F	COP	WPD		
		PSI	FT						PSI	FT						PSI	FT								
20	9.0	7.7	17.9	60	28.1	1.53	20.9	71.6	5.0	0.5	1.2	26.4	1.45	21.5	67.8	5.3	1.3	3.1	26.5	1.41	21.7	65.9	5.5	2.5	5.8
				80	25.7	1.96	19.0	91.4	3.8	0.4	0.9	25.9	1.86	19.6	87.7	4.1	1.2	2.8	25.9	1.81	19.8	85.8	4.2	2.3	5.4
				100	25.0	2.56	16.3	111.1	2.9	0.3	0.7	25.0	2.42	16.7	107.4	3.0	1.1	2.5	24.9	2.36	16.9	105.5	3.1	2.1	4.9
	4.5	1.7	4.0	60	27.1	1.54	21.9	72.1	5.2	0.5	1.2	27.5	1.45	22.5	68.1	5.5	1.3	3.1	27.6	1.42	22.7	66.1	5.7	2.5	5.8
				80	26.7	1.97	20.0	91.9	4.0	0.4	0.9	27.0	1.86	20.6	88.0	4.2	1.2	2.8	27.0	1.81	20.8	86.0	4.4	2.3	5.4
				100	26.1	2.56	17.3	111.6	3.0	0.3	0.7	26.1	2.43	17.8	107.7	3.2	1.1	2.5	26.0	2.36	18.0	105.8	3.2	2.1	4.9
				120	25.1	3.32	13.8	131.2	2.2	0.2	0.5	24.9	3.14	14.2	127.4	2.3	0.9	2.1	24.7	3.06	14.3	125.5	2.4	1.8	4.3
	30	6.8	4.1	60	28.4	1.54	23.2	72.6	5.4	0.5	1.2	28.8	1.46	23.8	68.5	5.8	1.3	3.1	28.9	1.42	24.1	66.4	6.0	2.5	5.8
				80	27.9	1.97	21.2	92.4	4.2	0.4	0.9	28.2	1.87	21.8	88.4	4.4	1.2	2.8	28.2	1.82	22.0	86.3	4.6	2.3	5.4
				100	27.1	2.57	18.3	112.0	3.1	0.3	0.7	27.2	2.43	18.9	108.0	3.3	1.1	2.5	27.1	2.37	19.0	106.0	3.4	2.1	4.9
				120	25.9	3.33	14.6	131.5	2.3	0.2	0.5	25.7	3.15	15.0	127.6	2.4	0.9	2.1	25.6	3.07	15.1	125.7	2.4	1.8	4.3
	9.0	7.1	16.4	60	29.2	1.54	23.9	73.0	5.5	0.5	1.2	29.6	1.46	24.6	68.8	5.9	1.3	3.1	29.7	1.42	24.8	66.6	6.1	2.5	5.8
				80	28.6	1.98	21.9	92.7	4.2	0.4	0.9	28.9	1.87	22.5	88.6	4.5	1.2	2.8	28.9	1.82	22.7	86.4	4.7	2.3	5.4
				100	27.7	2.58	18.9	112.3	3.2	0.3	0.7	27.8	2.44	19.5	108.2	3.3	1.1	2.5	27.7	2.37	19.6	106.2	3.4	2.1	4.9
				120	26.4	3.34	15.0	131.7	2.3	0.2	0.5	26.2	3.16	15.4	127.8	2.4	0.9	2.1	26.1	3.08	15.6	125.8	2.5	1.8	4.3
40	4.5	1.5	3.5	60	30.0	1.55	24.7	93.3	5.7	0.4	0.9	30.4	1.46	25.4	89.0	6.1	1.2	2.8	30.5	1.42	25.7	86.8	6.3	2.3	5.4
				80	29.0	2.26	21.3	112.9	3.8	0.3	0.7	29.2	2.14	21.9	108.7	4.0	1.1	2.5	29.3	2.08	22.2	106.5	4.1	2.1	4.9
				100	28.6	2.58	19.8	132.7	3.2	0.2	0.5	28.7	2.44	20.3	128.5	3.4	0.9	2.1	28.6	2.38	20.5	126.4	3.5	1.8	4.3
				120	31.4	1.55	26.1	74.0	5.9	0.5	1.2	31.9	1.47	26.9	89.5	6.4	1.3	3.1	32.0	1.43	27.2	87.1	6.6	2.5	5.8
	6.8	3.7	8.6	60	30.8	1.99	24.0	93.7	4.5	0.4	0.9	31.1	1.88	24.7	89.2	4.8	1.2	2.8	31.2	1.83	24.9	86.9	5.0	2.3	5.4
				80	29.7	2.59	20.9	113.2	3.4	0.3	0.7	29.9	2.45	21.5	108.9	3.6	1.1	2.5	29.8	2.38	21.7	106.6	3.7	2.1	4.9
				100	28.3	3.35	16.9	132.6	2.5	0.2	0.5	28.2	3.17	17.4	128.4	2.6	0.9	2.1	28.1	3.09	17.6	126.2	2.7	1.8	4.3
				120	32.2	1.55	26.9	74.3	6.1	0.5	1.2	32.7	1.47	27.7	89.7	6.5	1.3	3.1	32.9	1.43	28.0	87.3	6.7	2.5	5.8
	9.0	6.5	15.1	60	31.5	1.99	24.7	94.0	4.6	0.4	0.9	31.9	1.89	25.4	89.4	5.0	1.2	2.8	31.9	1.84	25.7	87.1	5.1	2.3	5.4
				80	30.4	2.59	21.5	113.5	3.4	0.3	0.7	30.5	2.45	22.2	109.0	3.6	1.1	2.5	30.5	2.39	22.4	106.8	3.7	2.1	4.9
				100	28.9	3.36	17.4	132.8	2.5	0.2	0.5	28.8	3.18	17.9	128.5	2.7	0.9	2.1	28.7	3.09	18.1	126.4	2.7	1.8	4.3
				120	28.9	3.36	17.4	127.7	2.5	0.2	0.5	28.8	3.18	17.9	125.3	2.7	0.9	2.1	28.7	3.09	18.1	124.0	2.7	1.8	4.3

•Objectives: GeoDesigner for System Design



•Objectives: Job Info / Load Info

Project Information

Job Information **Load Information**

Design Data

State/Prov.	City
IA	Evansville
ID	Fort Wayne
IL	Indianapolis
IN	South Bend

City Information

Degree Days	Deep Earth Temp F	Surface Swing F	Surface Swing Days	1% Clg Design F	97.5% Htg Design
5699	55	23.6	34	92	2

Load Input

	Heating	Cooling	Hot Water
Load Btu/Hr	73452	35698	
Delta T	72 F	25 F	125 F
Set Point	72 F	75 F	
Begin At		73 F	
Sensible Btu/Hr		31218	4 #
Users	<input type="checkbox"/> Ratio		

Internal Gains Estimator

Base Electric Load per sq ft

Low High

Solar Gains per sq ft

Low High

Occupancy Level per sq ft

Low High

Construction Quality

Low High

Blg Bal Point F Internal Gain Btu/Hr

Min. Heating Cd Factor Max.

Continuous Fan Yes No

Help **JobTab** **Done**

•Objectives: Main Screen, Utilities and Select System Types

Utility Information

Energy Providers

Utility - Electric	Sample Electric	Utility - Natural Gas	Sample Natural Gas
Source - Propane	Sample Propane	Source - Fuel Oil	Sample Fuel Oil

System Types

System Descriptions	Geo A	Geo B	H.P.	Furnace	None
<input type="checkbox"/> Gas-93%-Condensing-2stg-Vspd System	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
<input type="checkbox"/> 15 SEER - Scroll - R410a System	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
<input type="checkbox"/> TT 049 Vspd / Vert 1 U-Tube - 0.75"	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

Fuel Oil	3.000	Per Gallon	3.000	Per Gallon
----------	-------	------------	-------	------------

Help **Done**

Objectives: Select Heat Pumps Software

Building Design Loads / Example

Notes: Any HVAC Customer

Notes: Any MN GSHP Asoc Dealer

Design Data

Heating Load: 84,629 Btu/Hr

Htg Load Temp Diff: 85 Deg F

Cooling Load: 31,289 Btu/Hr

Clg Load Temp Diff: 20 Deg F

Sensible Cooling: 27,826 Btu/Hr

Reference City: Minneapolis, MN

Winter Design: -12 Deg F

Summer Design: 92 Deg F

Bldg Balance Temp: 61 Deg F

Avg Internal Gains: 11,067 Btu/Hr

Heating Setpoint: 72 Deg F

Cooling Setpoint: 75 Deg F

Begin Cooling At: 73 Deg F

Hot Water Setpoint: 130 Deg F

Hot Water Users: 4

Continuous Fan: No

Annual Heating: 169.1 Million Btu

Annual Cooling: 14.4 Million Btu

Annual Water Heating: 22.1 Million Btu

Daily Hot Water Use: 70 Gallons

•Objectives: Select Geo Unit, Loop Type and H2O Heating Method

GeoDesigner A GeoDesigner A GeoDesigner A GeoDesigner A

ClimateMaster
TT 049 Vspd
TT 049 Vspd
TT 064 Vspd
TT 072 Vspd
TT Tons Vspd
TTP 026 Vspd
TTP 038 Vspd
TTP 049 Vspd
TTP 064 Vspd

ClimateMaster
TT 049 Vspd
Hot Water G
Yes

ClimateMaster System
TT 049 Vspd

Hot Water Generator
Yes

Auxiliary Heat Selection
Electric Fan Coil - Vspd

Auxiliary Heat Operation Mode
Supplement Heat Pump

Geo Source
Vert 1 U-Tube

Geo Source Selection
Vert 1 U-Tube - 0.75"

Avg Depth
100 FT

Auto-Size

Loop Min/Max
32 95 Deg F

Water Heater Selection
Gas - Tankless - Hi Eff

Gas - Tankless - Hi Eff

Gas - Tank - Std

Gas - Tankless - Hi Eff

Geothermal - Full Time

Oil - Tank - Std

Propane - Tank - Hi Eff

Propane - Tank - Std

Propane - Tankless - Hi Eff

Solar Thermal - Electric Tank

Geo Source
Vert 1 U-Tube

Avg Depth

Auto-Size

Loop Min/Max

Soil
0.90 - Damp

Soil Selection
0.90 - Damp Sand/Gravel

Run Bin Analysis... Help Done


Gas - Tankless - Hi Eff



Objectives: Select Heat Pumps **Software Program**

Select Unit Via Drop Down Menu

Packaged, Split or W 2 W Units



Objectives: Select Heat Pumps Software

Percentage of Annual Heating Load / 4 Ton

TT 049 Vspd / Vert 1 U-Tube - 0.75"		
Geothermal Source	Heating	
Bore Length:	1,010 Feet	Geothermal
Max Cooling:	68 Deg F	3.59 COP
Avg Cooling:	56 Deg F	85 % of Htg
Avg Heating:	33 Deg F	\$874 Annual
Min Heating:	30 Deg F	Aux Heating
Deep Earth Temp:	47 Deg F	100 % Eff
Soil Conductivity:	0.90	15 % of Htg
Soil Diffusivity:	0.64	\$575 Annual
		Tot Heating
		\$1,449 Annual

Objectives: Select Heat Pumps Software

Percentage of Annual Heating Load / 5 Ton

TT 064 Vspd / Vert 1 U-Tube - 0.75"		
Geothermal Source	Heating	
Bore Length:	<u>1,280 Feet</u>	3.56 COP
Max Cooling:	63 Deg F	<u>93 % of Htg</u>
Avg Cooling:	53 Deg F	\$972 Annual
Avg Heating:	35 Deg F	100 % Eff
Min Heating:	30 Deg F	7 % of Htg
Deep Earth Temp:	47 Deg F	\$254 Annual
Soil Conductivity:	0.90	
Soil Diffusivity:	0.64	
	Tot Heating	\$1,226 Annual

Objectives: Select Heat Pumps Software

Percentage of Annual Heating Load / 6 Ton

TT 072 Vspd / Vert 1 U-Tube - 0.75"		
Geothermal Source	Heating	
Bore Length:	1,315 Feet	Geothermal
Max Cooling:	62 Deg F	3.00 COP
Avg Cooling:	53 Deg F	96 % of Htg
Avg Heating:	36 Deg F	\$1,185 Annual
Min Heating:	30 Deg F	Aux Heating
Deep Earth Temp:	47 Deg F	100 % Eff
Soil Conductivity:	0.90	4 % of Htg
Soil Diffusivity:	0.64	\$165 Annual
		Tot Heating
		\$1,350 Annual

Objectives: Select Heat Pumps Software

Operating Cost / 4 Ton Versus 5 Ton

Estimated Operating Cost Summary

System	Heating Cost	Cooling Cost	Hot Water Cost	Constant Fan	Total Cost	Per Month
TT 049 Vspd / Vert 1 U-Tube - 0.75"	\$1,449	\$31	\$305	\$0	\$1,786	\$149
TT 064 Vspd / Vert 1 U-Tube - 0.75"	\$1,226	\$29	\$319	\$0	\$1,574	\$131
No Option Selected	\$0	\$0	\$0	\$0	\$0	\$0

Comments:

Sizing a GSHP System

1122012

MN Sizing GSHP 2012.ged

Utility Cost	Rate	Summer	Winter
Electric - Geothermal	\$/kwh	.075	.075
Electric - Heat Pump	\$/kwh	.075	.075
Electric - Furnace	\$/kwh	.075	.075
Natural Gas	\$/therm	1.00	1.00
Propane	\$/gallon	2.25	2.25
Fuel Oil	\$/gallon	3.00	3.00

Objectives: Select Heat Pumps Software

Operating Cost / 5 Ton Versus 6 Ton

Estimated Operating Cost Summary

System	Heating Cost	Cooling Cost	Hot Water Cost	Constant Fan	Total Cost	Per Month
TT 064 Vspd / Vert 1 U-Tube - 0.75"	\$1,226	\$29	\$319	\$0	\$1,574	\$131
TT 072 Vspd / Vert 1 U-Tube - 0.75"	\$1,350	\$34	\$327	\$0	\$1,710	\$143
No Option Selected	\$0	\$0	\$0	\$0	\$0	\$0

Objectives: Select Heat Pumps Software

Operating Cost 5 Ton Geo VS Gas AC & ASHP

Estimated Operating Cost Summary

System	Heating Cost	Cooling Cost	Hot Water Cost	Constant Fan	Total Cost	Per Month
Gas-93%-Condensing-2stg-Vspd System	\$1,972	\$105	\$381	\$0	\$2,458	\$205
14 SEER - Scroll - R410a System	\$2,219	\$110	\$551	\$0	\$2,881	\$240
TT 064 Vspd / Vert 1 U-Tube - 0.75"	\$1,226	\$29	\$319	\$0	\$1,574	\$131

Comments:

Sizing a GSHP System


1122012

MN Sizing GSHP 2012.ged

Utility Cost	Rate	Summer	Winter
Electric - Geothermal	\$/kwh	.075	.075
Electric - Heat Pump	\$/kwh	.075	.075
Electric - Furnace	\$/kwh	.075	.075
Natural Gas	\$/therm	1.00	1.00
Propane	\$/gallon	2.25	2.25
Fuel Oil	\$/gallon	3.00	3.00

Objectives: Select Heat Pumps Latent Capacity

Typical Indoor Humidity Levels Maintained at 50/55% RH



Objectives: Select Heat Pumps Latent Load

Determine Latent Cooling Load

Notes: Any HVAC Customer

Notes: Any MN GSHP Asoc Dealer

Design Data

Heating Load: 84,629 Btu/Hr

Htg Load Temp Diff: 85 Deg F

Cooling Load: 31,289 Btu/Hr

Clg Load Temp Diff: 20 Deg F

Sensible Cooling: 27,826 Btu/Hr

Reference City: Minneapolis, MN

Winter Design: -12 Deg F

Summer Design: 92 Deg F

Bldg Balance Temp: 61 Deg F

Avg Internal Gains: 11,067 Btu/Hr

Heating Setpoint: 72 Deg F

Cooling Setpoint: 75 Deg F

Begin Cooling At: 73 Deg F

Hot Water Setpoint: 130 Deg F

Hot Water Users: 4

Continuous Fan: No

Annual Heating: 169.1 Million Btu

Annual Cooling: 14.4 Million Btu

Annual Water Heating: 22.1 Million Btu

Daily Hot Water Use: 70 Gallons

Latent Load =
Total Minus
Sensible

31,289 –
27,826 =
3,463 Latent

Objectives: Select Heat Pumps

Check Spec Catalog Data at Design EWT

EWT °F	GPM	WPD		COOLING - EAT 80/67 °F							HEATING - EAT 70°F							
		PSI	FT	Airflow CFM	TC	SC	kW	HR	EER	HWC	Airflow CFM	HC	kW	HE	LAT	COP	HWC	
20	7.5	0.8	1.9	1580 1825	Operation not recommended							Operation not recommended						
	11.3	2.4	5.5	1580 1825								Operation not recommended						
	15.0	5.0	11.6	1580 1825								1750 2050	41.0 41.8	3.86 3.71	27.8 29.1	91.7 88.9	3.12 3.30	4.0 3.5
30	7.5	0.6	1.5	1580 1825	66.0 67.3	42.1 45.6	2.79 2.90	75.5 77.2	23.7 23.2	-	1750 2050	44.6 45.4	3.87 3.73	31.4 32.7	93.6 90.5	3.38 3.57	4.1 3.6	
	11.3	2.3	5.3	1580 1825	67.0 68.3	42.6 46.2	2.67 2.77	76.1 77.8	25.1 24.7	-	1750 2050	46.4 47.3	3.92 3.77	33.0 34.4	94.6 91.4	3.47 3.67	4.1 3.5	
	15.0	4.8	11.0	1580 1825	68.4 69.7	43.5 47.1	2.61 2.71	77.3 78.9	26.2 25.7	-	1750 2050	47.4 48.3	3.95 3.80	34.0 35.4	95.1 91.8	3.52 3.73	4.0 3.5	

Cooling 5 Ton at 1825 CFM

60	7.5	0.3	0.8	1580 1825	66.0 67.3	43.9 47.6	3.58 3.72	78.2 80.0	18.5 18.1	2.9 3.0	1750 2050	63.0 64.2	4.47 4.29	47.8 49.5	103.3 99.0	4.14 4.38	4.8 4.2
	11.3	2.1	4.7	1580 1825	67.5 68.8	44.3 48.0	3.36 3.50	78.9 80.7	20.1 19.7	2.5 2.5	1750 2050	66.0 67.2	4.55 4.38	50.5 52.7	104.9 102.7	4.25 4.50	4.7 4.1
	15.0	4.1	9.4	1580 1825	68.0 69.4	44.4 48.1	3.26 3.39	79.2 80.9	20.9 20.5	2.1 2.1	1750 2050	67.0 68.9	4.00 4.43	52.8 53.8	106.2 101.1	4.31 4.57	4.7 4.0
70	7.5	0.3	0.7	1580 1825	63.3 64.6	43.1 46.7	3.92 4.08	76.7 78.5	16.1 15.8	4.0 4.0	1750 2050	69.5 70.9	4.66 4.48	53.6 55.7	106.8 102.7	4.38 4.55	5.3 4.6
	11.3	2.0	4.5	1580 1825	65.3 66.5	43.7 47.3	3.68 3.82	77.8 79.6	17.7 17.4	3.4 3.4	1750 2050	73.0 74.3	4.76 4.58	56.7 58.7	108.6 103.6	4.49 4.76	5.2 4.5
	15.0	3.9	8.9	1580 1825	66.2 67.5	44.0 47.6	3.56 3.70	78.3 80.1	18.6 18.2	2.8 2.9	1750 2050	75.0 76.5	4.82 4.63	59.5 60.5	109.7 105.5	4.56 4.83	5.1 4.4
80	7.5	0.2	0.5	1580 1825	60.0 61.2	41.9 45.4	4.33 4.50	74.8 76.6	13.9 13.6	5.2 5.3	1750 2050	76.2 77.6	4.86 4.67	59.6 61.7	110.3 105.1	4.60 4.87	5.8 5.1
	11.3	1.9	4.4	1580 1825	62.3 63.5	42.7 46.3	4.05 4.21	76.1 77.9	15.4 15.1	4.4 4.5	1750 2050	78.2 81.7	4.94 4.79	63.2 65.4	112.5 106.9	4.72 5.00	5.7 5.0
	15.0	3.6	8.4	1580	63.4	43.1	3.91	76.8	16.2	3.6	1750	82.6	5.05	65.3	113.7	4.79	5.6

Latent = TC - SC

69,440 - 48,100 =

11,340 LATENT

CAPACITY

Objectives: Select Heat Pumps Software

Cooling Run Time for Dehumidification

Temperature Bin Analysis

TT 064 Vspd / Vert 1 U-Tube - 0.75"

Outdoor Air Temp	Annual Weather Hours	Space Load Btu/Hr	Hot Water Load Btu/Hr	Geo Source Temp	Htg - Clg Capacity Btu/Hr	H.W. Gen Capacity Btu/Hr	Geo Run Time	Geo Operating Cost	Aux Heating Cost	Aux Hot Water Cost
112										
107										
102										
97	1	33,311	2,521	63	50,499	2,880	66%	\$0.12		\$0.02
92	32	28,256	2,521	60	51,238	2,583	55%	\$3.22		\$0.88
87	127	23,200	2,521	57	51,976	2,286	45%	\$9.99		\$4.76
82	267	18,145	2,521	53	52,712	1,990	34%	\$15.64		\$12.24
77	430	13,089	2,521	50	53,446	1,695	24%			\$22.61
72	617		2,521							\$38.84

50% Run Time?

Dehumidification Feature

Unit Sized for Full Heating/Oversized Cooling

Dehumidification Mode settings: The dehumidification mode setting provides field selection of humidity control. When operating in the normal mode, the cooling airflow settings are determined by the cooling tap setting above. When dehumidification is enabled there is a reduction in airflow in cooling to increase the moisture removal of the heat pump. Consult submittal data or specifications catalog for the specific unit series and model to correlate speed tap to airflow in CFM. The dehumidification mode can be enabled in two ways.

Constant Dehumidification Mode: When the dehumidification mode is selected (via DIP switch or jumper setting), the ECM motor will operate with a multiplier applied to the cooling CFM settings (approx. 20-25% lower airflow). Any time the unit is running in the cooling mode, it will operate at the lower airflow to improve latent capacity. The "DEHUM" LED will be illuminated at all times. Heating airflow is not affected. NOTE: Do not select dehumidification mode if cooling

Dehumidification Feature

Unit Sized for Heating/Oversized Cooling


Model	Max ESP (in. wg)	Fan Motor (hp)	Tap Setting	Cooling Mode			Dehumid Mode			Heating Mode			AUX CFM	Aux/Emerg Mode
				Stg 1	Stg 2	Fan	Stg 1	Stg 2	Fan	Stg 1	Stg 2	Fan		
026	0.50	1/2	4	810	950	475	630	740	475	920	1060	475	4	1060
	0.50	1/2	3	725	850	425	560	660	425	825	950	425	3	950
	0.50	1/2	2	620	730	370	490	570	370	710	820	370	2	820
	0.50	1/2	1	520	610	300				600	690	300	1	690
038	0.50	1/2	4	1120	1400	700	870	1090	700	1120	1400	700	4	1400
	0.50	1/2	3	1000	1250	630	780	980	630	1000	1250	630	3	1350
	0.50	1/2	2	860	1080	540	670	840	540	860	1080	540	2	1350
	0.50	1/2	1	730	900	450				730	900	450	1	1350
049	0.75	1	4	1460	1730	870	1140	1350	870	1560	1850	870	4	1850
	0.75	1	3	1300	1550	780	1020	1210	780	1400	1650	780	3	1660
	0.75	1	2	1120	1330	670	870	1040	670	1200	1430	670	2	1430
	0.75	1	1	940	1120	560				1010	1200	560	1	1350
064	0.75	1	4	1670	2050	1020	1300	1600	1020	1860	2280	1020	4	2280
	0.75	1	3	1500	1825	920	1160	1430	920	1650	2050	920	3	2040
	0.75	1	2	1280	1580	790	1000	1230	790	1430	1750	790	2	1750
	0.75	1	1	1080	1320	660				1200	1470	660	1	1470

064

Objectives: Select Heat Pumps

Software: W to W

Select Unit Via Drop Down Menu



Objectives: Select Heat Pumps Software

Operating Cost / 5 Ton W 2 W Versus 5 Ton W to A

Estimated Operating Cost Summary

System	Heating Cost	Cooling Cost	Hot Water Cost	Constant Fan	Total Cost	Per Month
TMW 060 110F Load / Vert 1 U-Tube - 0.75"	\$1,283	\$11	\$162	\$0	\$1,455	\$121
TT 064 Vspd / Vert 1 U-Tube - 0.75"	\$1,226	\$29	\$319	\$0	\$1,574	\$131
No Option Selected	\$0	\$0	\$0	\$0	\$0	\$0

Comments:

Sizing a GSHP System

1122012

MN Sizing GSHP 2012.ged

Utility Cost	Rate	Summer	Winter
Electric - Geothermal	\$/kwh	.075	.075
Electric - Heat Pump	\$/kwh	.075	.075
Electric - Furnace	\$/kwh	.075	.075
Natural Gas	\$/therm	1.00	1.00
Propane	\$/gallon	2.25	2.25
Fuel Oil	\$/gallon	3.00	3.00

Objectives: Design Loop System

Common Information

Loop Design

Basic Design Rules

3 GPM Per Ton of Equipment

Pressure / Temperature Ports on ALL Units

1 - 3/4" PE Circuit per ton / 3 GPM

1 1/4" or 2" PE Pipe for Supply & Return

Reverse Return Header for Equal Flow

Objectives: Design Loop System

Complete a Site Survey


Geo Site Survey

Client Name: _____ Address: _____ Date: _____
Phone: _____ Surveyed by: _____ New construction Retrofit
GeoDesigner performed by: _____ Phone: _____ Date: _____
Soil conditions: _____
Special conditions and requirements: _____ Permit number: _____
Owner's preference on location of loop: _____

Locate property lines, existing structures, future construction, utilities, and services.
Also locate the geo unit, earth loop, penetration etc.

Scale 1 small square = _____ ft.

N



Legend:

- Power Lines:
 overhead
 underground
- Telephone Lines:
 overhead
 underground
- TV Cable:
 overhead
 underground
- Water Well Depth _____ ft.
- City Water
- Natural Gas
- Propane
- City Sewer
- Private Sewer
- Easements
- Fuel Lines
- Lawn Sprinkler
- Drain Tile
- Bldg. Penetration
- Unit location
- Existing condensing unit
- Pond Size _____
Avg. Depth _____
Min. Depth _____
- Other _____

Establish Which Type of Loop Will Work best for This Design

Follow Check List on the Geo Site Survey Form

Plan a Completed "As Built" Drawing for Entire Ground Loop

Objectives: Design Loop System Common Information


GeoDesigner Worksheet

 CLIMATEM Geothermal Heat P		Dealer Information Name: _____ Address: _____ City/State/Zip: _____ Phone: _____ Fax: _____ Date: _____		Client Information Name: _____ Address: _____ City/State/Zip: _____ Phone: _____ Fax: _____ Building Notes: _____ Project #: _____															
How many people in home Existing equipment Any allergies or concerns Home ever too hot or cold Any hot or cold water system Do you want a system Concerned with energy Aware of the impact Any special needs Concerned with energy Des Aware of the impact Any special needs Des Any special safety Des A lake or pond nearby Special trees or plants Are you aware of When do you plan to Do you know about Do either of you What types of energy What are you considering How long have you Typical savings from invested money If financing, what What is the interest What is the term Would you be interested What are the 5 reasons <input type="checkbox"/> low cost operation <input type="checkbox"/> clean operation <input type="checkbox"/> odorless <input type="checkbox"/> no noisy outdoor <input type="checkbox"/> free hot water <input type="checkbox"/> environmentally friendly If you had to choose Are there any other If yes _____ How many bids How many bids How many more Customer: _____ Customer: _____		Load Information City Selection: _____ <table border="1"> <tr> <td>Load</td> <td>dT</td> <td>Setpt</td> </tr> </table> Heating: _____ Cooling: _____ Sens Clg Load: _____ Begin Clg At: _____		Load	dT	Setpt	Internal Gains (1-low 5-high): Base Electric Load per ft ² : _____ Solar Gain per ft ² : _____ Occupancy per ft ² : _____ Construct or Load per ft ² : _____ Hot Water Setpoint: _____ Hot Water Users: _____												
Load	dT	Setpt																	
Geo A Information Unit Model: _____ # of Tons: _____ HWG: _____ Ultra Hybrid: _____ Loop Type: _____ Avg Depth: _____ Trench/Bore: _____ Loop Temp Range: _____ Soil Type: _____		Geo B Information Unit Model: _____ # of Tons: _____ HWG: _____ Ultra Hybrid: _____ Loop Type: _____ Avg Depth: _____ Trench/Bore: _____ Loop Temp Range: _____ Soil Type: _____		Utility Rates <table border="1"> <tr> <td>Summer</td> <td>Winter</td> </tr> <tr> <td>Electric Geo:</td> <td>_____</td> </tr> <tr> <td>Electric HP:</td> <td>_____</td> </tr> <tr> <td>Electric Fossil:</td> <td>_____</td> </tr> <tr> <td>Natural Gas:</td> <td>_____</td> </tr> <tr> <td>Propane:</td> <td>_____</td> </tr> <tr> <td>Fuel Oil:</td> <td>_____</td> </tr> </table> <small>Denotes required information</small>		Summer	Winter	Electric Geo:	_____	Electric HP:	_____	Electric Fossil:	_____	Natural Gas:	_____	Propane:	_____	Fuel Oil:	_____
Summer	Winter																		
Electric Geo:	_____																		
Electric HP:	_____																		
Electric Fossil:	_____																		
Natural Gas:	_____																		
Propane:	_____																		
Fuel Oil:	_____																		
Heat Pump Information Model: _____ ARI Clg Capacity: _____ Cut Off Temp: _____ Aux Heat Type: _____ Input Capacity: _____		Furnace Information Furnace Model: _____ Input Capacity: _____ Air Cond Type: _____ ARI Clg Capacity: _____																	

Complete the Questionnaire
 Determine Proper Location and Method for Building Entry with Supply & Return Piping System And Location of Pump Station

Objectives: Design Loop System Reverse Return

Loop Design



Objectives: Design Loop System

Vertical

Vertical Loops

One bore per ton

Bore hole spacing 10 ft minimum

One circuit at 3 GPM flow per ton for 3/4" and 1" circuits

U-Bend pipe sizes 3/4" & 1" ID

ASTM PE3408 HD Geothermal PE pipe

Many states require bentonite grouting


Some locales restrict drilling

Bore Hole Depth (typical)

North 150 -300 ft/ton

South 200 - 450 ft/ton

Objectives: Design Loop System Software Program



Objectives: Design Loop System Vertical



Drilling



Pipe Loop
Insertion




Heat Fusing



Pressure
Testing

•Multiple Hole Vertical Loop

- Supply & Return Piping exit straight out from building foundations- 10 feet min.
- Header Pit should be 10 feet min. from building foundation



- Simple drawing shows typical bore hole/circuit layout.
- Actual Header Manifold less than 24" long.
- Parallel circuit piping 3/4" & 1.0" dia. Pipe sizes

Objectives: Design Loop System Vertical

Our 5 Ton Design with Vertical Loops

One bore per ton

Bore hole spacing 10 ft
minimum

**One circuit at 3 GPM
flow per ton for 3/4"
circuits**

**1280 / 5 Tons =
255 Feet of
Bore per Hole**

5 Circuits at 510 FT each

TT 064 Vspd / Vert 1 U-Tube - 0.75"		
Geothermal Source	Heating	
Bore Length:	1,280 Feet	Geothermal
Max Cooling:	63 Deg F	3.56 COP
Avg Cooling:	53 Deg F	93 % of Htg
Avg Heating:	35 Deg F	\$972 Annual
Min Heating:	30 Deg F	
Deep Earth Temp:	47 Deg F	
Soil Conductivity:	0.90	Aux Heating
Soil Diffusivity:	0.64	100 % Eff
		7 % of Htg
		\$254 Annual
		Tot Heating
		\$1,226 Annual

Objectives: Design Loop System

Horizontal

Horizontal Loops

Backhoe or trench excavation

Backhoe used in areas with rock

Loop Piping installed below frost line

¾" & 1" ID PE3408 HD PE pipe

1 circuit per ton using ¾" and 1" circuits



3 gpm flow/ton

Pipe per ton

North 600 ft - 1200 ft

South 700 ft - 1800 ft

Objectives: Design Loop System Software Program



Objectives: Design Loop System



Trenching



Pit Loops




Horizontal
Boring

Four-Pipe Horizontal Loop

- Supply/Return Pipes

- Exit Perpendicular
 - to Foundation Wall
 - Header Pit Min. 10 ft.
 - from Wall



- Typical Trench/Circuit layout

- 24" Maximum Header/Manifold
- Parallel Circuit Design
- 3/4" or 1" Circuit Pipe

Objectives: Design Loop System Horizontal Trench

Our 5 Ton Design with a 4 pipe Horizontal Loop

OPTION # 1

**Backhoe or trench
excavation**

**1 circuit per ton
using 3/4"
circuits**

8 feet AVG Depth

**870 total feet / 2
= 2 trenches at
435 feet each**

**4 Circuits at 900
FT each**

TT 064 Vspd and Horz 4 pipe - 0.75"		
Geothermal Source	Heating	
Trench Length:	870 Feet	3.66 COP 95 % of Htg \$963 Annual
Max Cooling:	64 Deg F	
Avg Cooling:	52 Deg F	
Avg Heating:	38 Deg F	100 % Eff 5 % of Htg \$193 Annual
Min Heating:	30 Deg F	
Deep Earth Temp:	47 Deg F	
Soil Conductivity:	0.90	
Soil Diffusivity:	0.64	Tot Heating \$1,157 Annual

OPTION # 2





1 circuit per ton using 3/4" circuits

**870 total feet / 3 = 3 trenches at 290 feet
each**

6 Circuits at 600 FT each

Objectives: Design Loop System Software Program

Slinky Horizontal and Bore Loops



Objectives: Design Loop System

Horizontal Bore

Our 5 Ton Design with a Horizontal Bore Loop

Horizontal Bore

**1 circuit per ton
using 3/4"
circuits**

15 feet AVG Depth

**1,100 total feet / 5
= 5 trenches at
220 feet each**

**5 Circuits at 440 Ft
each**

TT 064 Vspd and Horz U-Tube - 0.75"		
Geothermal Source	Heating	
Bore Length:	1,100 Feet	Geothermal 3.64 COP 94 % of Htg \$960 Annual
Max Cooling:	64 Deg F	Aux Heating 100 % Eff 6 % of Htg \$226 Annual
Avg Cooling:	51 Deg F	
Avg Heating:	37 Deg F	
Min Heating:	30 Deg F	
Deep Earth Temp:	47 Deg F	
Soil Conductivity:	0.90	
Soil Diffusivity:	0.64	
	Tot Heating	\$1,186 Annual

Objectives: Design Loop System Pond / Lake

Lake or Pond Loop

Least expensive ground loop

Minimum 1/2 acre and 10 feet deep

Pond should be within 400' of structure

In North - need ice cover for good operation

Utilizes 39°F water temp (no aeration).


Stagnate water body works best for heating

Pipe footage per ton / circuit

North and South 400 ft -500 ft/ton

3/4" ASTM PE3408 HD PE pipe

Objectives: Design Loop System Pond / Lake



Lake Loop Coils on Rack



Objectives: Design Loop System Pond / Lake

Plate Heat Exchangers




Floating Coils



Pond Loop Layout

- Supply/Return Pipes
 - Exit Perpendicular
 - to Foundation Wall



- Typical Trench/Circuit layout
 - Extended Reverse Return
 - Header/Manifold
 - Parallel Circuit Design
 - 3/4" or 1" HD PE3408 pipe

Objectives: Design Loop System Pond / Lake

One Circuit per ton

Lake or Pond Loop

Some spacing required
between coils or
slinky

**USE - One circuit
per Ton at 400
FEET and 3 GPM
flow per ton for 3/4"
circuits**


**2000 / 5 Tons
= 400 Feet of
PE Pipe per
Circuit w 5
Total**

TT 064 Vspd and Pond Loop - Coiled 0.75"		
Geothermal Source	Heating	
Pipe Length: 1,500 Feet	Geothermal	3.54 COP 94 % of Htg \$983 Annual
Max Cooling: 76 Deg F	Aux Heating	100 % Eff 6 % of Htg \$234 Annual
Avg Cooling: 65 Deg F		
Avg Heating: 34 Deg F		
Min Heating: 29 Deg F		
Deep Earth Temp: 47 Deg F	Tot Heating	\$1,218 Annual
Soil Conductivity: 0.00		
Soil Diffusivity: 0		

**Heating Dominant Loads in a Northern
Climate Should USE 400 Feet of 3/4" PE
Pipe per Ton / Not 300' / Ton**

**Minimum 1/2 acre / 24,000 SQ FT and a
MINIMUM of 10 feet deep**

Quick Connect Test Caps – Examples (McElroy Mfg.)



Water Side Of System

Flow Controller / Pump Station



Water Side Of System

Non Pressurized Pump Station



Objectives: Select Loop Circulator Pumps

Pump Selection

Pump Selection

- Verify 1 or 2 Pump Flow Controller
- **1 Pump = 3 Ton Unit**
- **2 Pump = 3.5 to 6 Tons**
- Minimum Flow of 2.25 GPM / Ton
- Verify Reynolds Number at 2500 Min.
- Use Pressure Drop Software Program
- Flush Cart Capable of Proper Flow

Objectives: Effects on Loop Software

Total Bore 4 Ton, 5 Ton VS 6 Ton

TT 049 Vspd /		TT 064 Vspd / A		TT 072 Vspd / Vert 1	
Geothermal Source		Geothermal Source		Geothermal Source	
Bore Length:	1,010 Feet	Bore Length:	1,280 Feet	Bore Length:	1,315 Feet
Max Cooling:	68 Deg	Max Cooling:	63 Deg F	Max Cooling:	62 Deg F
Avg Cooling:	56 Deg	Avg Cooling:	53 Deg F	Avg Cooling:	53 Deg F
Avg Heating:	33 Deg	Avg Heating:	35 Deg F	Avg Heating:	36 Deg F
Min Heating:	30 Deg	Min Heating:	30 Deg F	Min Heating:	30 Deg F
Deep Earth Temp:	47 Deg	Deep Earth Temp:	47 Deg F	Deep Earth Temp:	47 Deg F
Soil Conductivity:	0.90	Soil Conductivity:	0.90	Soil Conductivity:	0.90
Soil Diffusivity:	0.64	Soil Diffusivity:	0.64	Soil Diffusivity:	0.64

Objectives: Select Loop Circulator Pumps

Vertical Example with Methanol



CLIMATEMASTER[®]

• [About](#) • [Contact](#) • [Privacy](#) • [Terms](#) • [Help](#) • [Feedback](#)

3. Inside Pipe s Minimum system flow rate should be 11 gpm.
8. Determine Pump Sizing Curve Coordinates:

$$\begin{aligned}
 \text{4. Outside Pipe } s: \\
 \text{Tot. gpm (3 gpm/ton)} &= \frac{Q_1 \quad 15.0}{x} \\
 \text{Tot. pres. drop (Ft hd)} &= \frac{h_1 \quad 37.7}{y} \\
 \text{Tot. gpm} \times 2/3 &= \frac{Q_2 \quad 10.0}{x} \\
 \text{PD} = (Q_2^2)(h_1) / (Q_1^2) &= \frac{h_2 \quad 16.8}{y} \\
 \text{Tot. gpm} \times 4/3 &= \frac{Q_3 \quad 20.0}{x} \\
 \text{PD} = (Q_3^2)(h_1) / (Q_1^2) &= \frac{h_3 \quad 67.1}{y}
 \end{aligned}
 \quad \left. \begin{aligned}
 &\text{point A} \\
 &\text{point B} \\
 &\text{point C}
 \end{aligned} \right\}$$

5. Circuit Pipe s 9. Plot system curve & determine which Flow Controller will produce the desired flow rate. Pump Sys B = 16 gpm (to the nearest gpm)

10. Verify circuit Reynolds number: 3578
(Should be 2,500 or greater)

11. Calculate the amount of antifreeze needed:

(Price: \$1.00) \times 10 = \$10.00

(Pipe size: 1.00) 10 tot. feet x

(Pipe size: 1.25) 200 tot. feet* x

(Pipe size: 0.75 } 2550 tot. feet* x

(Pipe size: _____) _____ tot. feet* x _____


1) Use decimal number for pipe size (e.g. 3/4)

3) Volume(100 ft³) is shown for PE pipe

3) Use 1" pipe for rubber hose.

Version 8.1

rev. 081809



$$4.5 \text{ volume/100 ft.} \div 100 = 0.5 \text{ gallons}$$

$$8.3 \text{ volume/100 ft.} \div 100 = 16.6 \text{ gallons}$$

$$\frac{3.8 \text{ volume/100 ft.} \div 100}{3.8 \text{ volume/100 ft.} \div 100} = \frac{31.4 \text{ gallons}}{31.4 \text{ gallons}}$$

$$\frac{2.8 \text{ volume/100 L}}{100} \div 100 = \frac{71.4 \text{ gallons}}{100}$$

Total fluid in loop: 99.5 gallons**

Total fluid in loop: 35.5 gallons
% antifreeze: 25% by vol

Total antifreeze req.: 34.9 gallons

Flushing requirements: 20 gpm @ 67 ft. head

Objectives: Select Loop Circulator Pumps

Vertical Example with Propylene Glycol

Customer: MN GSHPA 2012	Antifreeze (M,P,E or W): P	Propylene Glycol
Address: 5 Ton Vertical Example	% Antifreeze by vol.: 25	%
Address: _____	Number of circuits: 4	_____
<small>¹Note: M = Methanol; P = Propylene Glycol; E = Ethanol; W = Water</small>		
<small>²Note: Pump combo A = 1-UP26-99; pump combo B = 2-UP26-99; pump combo C = 2-UP26-116; pump combo D = 3-UP26-99</small>		
1. Unit #1: 4 (enter code from below)	TT_064	5 tons
		gpm 15

7. Total Pressure Drop (A + B + C + D + E): 46.4 ft. of hd.** F

Minimum system flow rate should be 11 gpm.

8. Determine Pump Sizing Curve Coordinates:

$$\text{Tot. gpm (3 gpm/ton)} = \frac{Q_1}{15.0} \quad \text{point A}$$

$$\text{Tot. pres. drop (Ft hd)} = \frac{h_1}{46.4} \quad \text{point A}$$

$$\text{Tot. gpm} \times \frac{2}{3} = \frac{Q_2}{10.0} \quad \text{point B}$$

$$\text{PD} = \frac{(Q_2^2)(h_1)}{(Q_1^2)} = \frac{h_2}{20.6} \quad \text{point B}$$


$$\text{Tot. gpm} \times \frac{4}{3} = \frac{Q_3}{20.0} \quad \text{point C}$$

$$\text{PD} = \frac{(Q_3^2)(h_1)}{(Q_1^2)} = \frac{h_3}{82.5} \quad \text{point C}$$

9. Plot system curve & determine which Flow Controller will produce the desired flow rate.

Pump Sys C = 16 gpm (to the nearest gpm)

10. Verify circuit Reynolds number: 2554
(Should be 2,500 or greater)



Objectives: Select Loop Circulator Pumps

Horizontal 4 Pipe w 4 Circuits Example

Customer: MN GSHPA 2012	Antifreeze (M,P,E or W)	M	Methanol
Address: 5 Ton Horizontal 4 Pipe Example	% Antifreeze by vol.:	25	%
Address: With 4 Circuits	Number of circuits:	4	


6. Fittings (Add 2 ft. of hd. for every 10 fittings): 18 (number of fittings) 3.6 ft. of hd. E
7. Total Pressure Drop (A + B + C + D + E): 58.1 ft. of hd.** F

Minimum system flow rate should be 11 gpm.

8. Determine Pump Sizing Curve Coordinates:
Tot. gpm (3 gpm/ton) = Q1 15.0 x } point A
Tot. pres. drop (Ft hd) = h1 58.1 y }
Tot. gpm x 2/3 = Q2 10.0 x } point B
PD=(Q2^2)(h1)/(Q1^2) h2 25.8 y }
Tot. gpm x 4/3 = Q3 20.0 x } point C
PD=(Q3^2)(h1)/(Q1^2) h3 103.4 y }

9. Plot system curve & determine which Flow Controller will produce the desired flow rate.
Pump Sys B = 13 gpm (to the nearest gpm)

10. Verify circuit Reynolds number: 3690
(Should be 2,500 or greater)



Objectives: Select Loop Circulator Pumps

Horizontal 4 Pipe w 6 Circuits Example

Customer: MN GSHPA 2012

Address: 5 Ton Horizontal 4 Pipe Example

Address: With 4 Circuits

Antifreeze (M,P,E or W) M Methanol

% Antifreeze by vol.: 25 %

Number of circuits: 6

Pump combination: B (2) UP26-99

¹Note: M = Methanol; P = Propylene Glycol; E = Ethanol; W = Water

7. Total Pressure Drop (A + B + C + D + E):

Minimum system flow rate should be 11 gpm.

8. Determine Pump Sizing Curve Coordinates:

$$\text{Tot. gpm (3 gpm/ton)} = \frac{Q_1}{15.0} \quad \text{point A}$$

$$\text{Tot. pres. drop (Ft hd)} = \frac{h_1}{35.9} \quad \text{point A}$$

$$\text{Tot. gpm} \times \frac{2}{3} = \frac{Q_2}{10.0} \quad \text{point B}$$

$$PD = \frac{(Q_2^2)(h_1)}{(Q_1^2)} = \frac{h_2}{15.9} \quad \text{point B}$$

$$\text{Tot. gpm} \times \frac{4}{3} = \frac{Q_3}{20.0} \quad \text{point C}$$

$$PD = \frac{(Q_3^2)(h_1)}{(Q_1^2)} = \frac{h_3}{63.8} \quad \text{point C}$$

9. Plot system curve & determine which Flow Controller will produce the desired flow rate.

Pump Sys B = 16 gpm (to the nearest gpm)

10. Verify circuit Reynolds number: 3019

(Should be 2,500 or greater)

Pipe size: 0.75 in.

Design GPM/ckt:

600 ft. of pipe* x

2.5

ft. of hd/100 ft. ÷ 100 =

1.81

10.86


Actual GPM/ckt =

2.7

gpm

ft. of hd.

D



Objectives: Select Loop Circulator Pumps

Lake Loop w 4 Circuits Example

5. Circuit Piping (Use only one circuit if piped using parallel header system; use total pipe if series loop):

$$\text{Pipe size: } 0.75 \text{ in.} \quad \text{Design GPM/ckt: } 3.8 \quad \text{Actual GPM/ckt} = 4.0 \text{ gpm}$$

$$500 \text{ ft. of pipe}^* \times 4.23 \text{ ft. of hd/100 ft.} \div 100 = 21.17 \text{ ft. of hd.} \quad D$$

6. Fittings (Add 2 ft. of hd. for every 10 fittings): $18 \text{ (number of fittings)} \times 3.6 \text{ ft. of hd.} = E$

7. Total Pressure Drop (A + B + C + D + E): $43.4 \text{ ft. of hd.}^{**} = F$

Minimum system flow rate should be 11 gpm.

8. Determine Pump Sizing Curve Coordinates:

$$\text{Tot. gpm (3 gpm/ton)} = Q_1 \quad 15.0 \quad x \quad \text{point A}$$

$$\text{Tot. pres. drop (Ft hd)} = h_1 \quad 43.4 \quad y \quad \text{point A}$$

$$\text{Tot. gpm} \times 2/3 = Q_2 \quad 10.0 \quad x \quad \text{point B}$$

$$PD = (Q_2^2)(h_1) / (Q_1^2) \quad h_2 \quad 19.3 \quad y \quad \text{point B}$$

$$\text{Tot. gpm} \times 4/3 = Q_3 \quad 20.0 \quad x \quad \text{point C}$$

$$PD = (Q_3^2)(h_1) / (Q_1^2) \quad h_3 \quad 77.2 \quad y \quad \text{point C}$$


9. Plot system curve & determine which Flow

Controller will produce the desired flow rate.

Pump Sys C = 16 gpm (to the nearest gpm)

10. Verify circuit Reynolds number: 2554

(Should be 2,500 or greater)



Objectives: System Performance Evaluation

Each Unit **MUST** Have Proper Startup

CLIMATEMASTER
Packaged Unit Refrigeration Schematic

COMMISSIONING WORKSHEET

Rev. 11/08

Job Name: _____ Date: _____ Antifreeze: _____

Model#: _____ Serial#: _____ Unit Tag #: _____

Wire Size: _____ Voltage: _____ Amps: _____

HEATING CYCLE ANALYSIS -

COOLING CYCLE ANALYSIS -

Objectives: Building Loads Commercial

Commercial - Calculate Building Loads using
ACCA Manual N or ASHRAE Method

Zone loads are used to select heat pumps


Peak block load is used to determine bore
loop depths

Heating and cooling loads are required for
each zone / area that will have a ground
loop system

Commercial Building Load Profile is
“Normally” Cooling Dominate


Objectives: Building Loads Commercial

UNIT LAYOUT- PERIMETER AND CORE DESIGN



Objectives: Building Loads Commercial


CENTRAL PUMP STATION APPLICATION



Objectives: Loop Design / Basic Commercial

Commercial Loop Layout

RUNOUT



**CIRCUIT or
BORE**

Objectives: Loop Design / Basic Commercial

USE Peak Building Load for Loop Size / AEFLH

Average Block Loads - Garber Church C 10 5 06 d

Garber Church C3 10 5 06

Reference Label: Garber Church C2 10 2 06

Design Day Loads

Design Day Loads			
Days Occupied per Week	Time of Day	Heat Gains (MBtu/Hr)	Heat Losses (MBtu/Hr)
7.0	8 a.m. - Noon	572.0	650.0
	Noon - 4 p.m.	715.0	305.0
	4 p.m. - 8 p.m.	430.0	200.0
	8 p.m. - 8 a.m.	180.0	300.0

Transfer

Calculate Hours

Annual Equivalent Full-Load Hours: 600 800

Heat Pump Specifications at Design Temperature and Flow Rate

Custom Pump Pump Name: GRV 036

	Cooling	Heating
Capacity (MBtu/Hr)	756.7	650.0
Power (kW)	61.66	55.51
EER/COP	12.3	3.4
Flow Rate (gpm)	178.8	162.5
Partial Load Factor	0.94	1.00

Flow Rate: 3.0 gpm/ton Unit Inlet (°F): 80.0 45.0

Four Time Periods

Annual Equivalent Full Load Hours

Objectives: Loop Design / Basic Commercial

Unit Sized to Peak Zone Load

Average Block Loads - Garber Church C 10 5 06 d

Garber Church C3 10 5 06

Reference Label: Garber Church C2 10 2 06

Design Day Loads

Days Occupied per Week	Time of Day	Heat Gains (MBtu/Hr)	Heat Losses (MBtu/Hr)
7.0	8 a.m. - Noon	572.0	650.0
	Noon - 4 p.m.	715.0	305.0
	4 p.m. - 8 p.m.	430.0	200.0
	8 p.m. - 8 a.m.	180.0	300.0

Transfer

Calculate Hours

Annual Equivalent Full-Load Hours: 600 800

Heat Pump Specifications at Design Temperature and Flow Rate

ClimateMaster

Pump Name: GS Vertical

GS Vertical
GR Horizontal
GR Vertical
GS Horizontal
GS Split
Paradigm
RE Rooftop
Ultra Classic - Full Load

Flow Rate: 3.0 gpm/ton

Unit Inlet (°F): 80.0 45.0

Equipment
Selection

Objectives: Loop Design / Vertical Loop Data

Borehole Design Project - 100 ton Example 7 22 09

Results | Fluid | Soil | U-Tube | Pattern | Extra kW | Information |

	COOLING	HEATING
Total Length (ft):	23946.6	11929.2
Borehole Number:	72	72
Borehole Length (ft):	332.6	165.7
Ground Temperature Change (°F):	+0.9	+1.7
Unit Inlet (°F):	90.0	35.0
Unit Outlet (°F):	100.3	29.5
Total Unit Capacity (kBtu/Hr):	1263.2	1105.5
Peak Load (kBtu/Hr):	1200.0	750.0
Peak Demand (kW):	101.7	67.4
Heat Pump EER/COP:	11.8	3.3
System EER/COP:	11.8	3.3
System Flow Rate (gpm):	300.0	187.5

Optional Cooling Tower/Boiler

Condenser Capacity (kBtu/hr):	0.0	Cooling Tower	0 %
Cooling Tower Flow Rate (gpm):	0.0	0 %
Cooling Range (°F):	10.0	Boiler	0 %
Annual Operating Hours (hr/yr):	0	0 %
Boiler Capacity (kBtu/hr):	0.0	Load Balance	0 %

Borehole Depth

System Flow Rate GPM

Optional “Hybrid” Design with Fluid Cooler or Boiler

Objectives: Finance Module

Life Cycle Analysis

S Finance Module - 100 ton Example 7 22 09

Results | Geothermal | Conventional | Utilities | Other Costs | Incentives

Alternate Systems

System:	1	COOLING	HEATING	TOTAL		
Total Annual Power:	78,000.0	kwh	0.0	kwh	78,000.0	kwh
Water:	0.0	Gallons	0.0	Gallons	0.0	Gallons
Other:	None		500,121.2	ft ³		Natural Gas

System Details

	COOLING	HEATING			
Eqv Full-Load Hours:	650	hr	550	hr	
Equipment Type:	Air-cooled Chiller		Boiler		
Power Source:	Electricity		Natural Gas		
Installed Capacity:	1200.0	kBtu/hr	750.0	kBtu/hr	
Efficiency:	10.0	EER	80.0	%	
Extra Power:	0.0	kW	0.0	kW	
Mech. Install Area:	0.0	ft ²	0.0	ft ²	
Water Usage Rate:	0.00	gpm/ton	0.00	gpm/ton	?

Conventional System Inputs

System Types

System Efficiency

Objectives: Finance Module

Life Cycle Analysis

Finance Module - 100 ton Example 7 22 09

Results Geothermal Conventional Utilities Other Costs Incentives

Geothermal System

	COOLING	HEATING	TOTAL
25.0 years	25.0	25.0	25.0
Geothermal Power:	49367.1 kwh	33582.5 kwh	82949.5 kwh
Hybrid Power:	0.0 kwh	0.0 kwh	0.0 kwh
Total Annual Power:	49367.1 kwh	33582.5 kwh	82949.5 kWh
Water:	0.0 Gallons	0.0 Gallons	0.0 Gallons
Other:	None	None	

Primary Geothermal **Hybrid Component**

	COOLING	HEATING
Eqv Full-Load Hours:	650 hr	550 hr
Peak Capacity:	1200.0 kBtu/hr	750.0 kBtu/hr
Average Heat Pump Efficiency:	15.8 EER	3.6 COP
Circulation Pump Input Power:	0.0 kW	0.0 kW
Circ. Pump Power:	0.0 hP	0.0 hP
Motor Efficiency:	85.0 %	85.0 %
Additional Power:	0.0 kW	0.0 kW

Mech. Room Installation Area: 0.0 ft²

Geothermal System Inputs

System Types

System Efficiency

Objectives: Finance Module

Life Cycle Analysis

Finance Module - 100 ton Example 7 22 09

Results | Geothermal | Conventional | Utilities | Other Costs | Incentives

Estimated Cost Results

Geothermal Alternate Air-cooled Chiller Boiler

	Geothermal	Alternate
Annual Costs (\$)		
Energy	5,806.47	21,463.88
CO2 Emissions	0.00	0.00
Water	0.00	0.00
Maintenance	0.00	0.00
Mechanical Room Lease	0.00	0.00
Annual Total	5,806.47	21,463.88
<i>NPV Lifecycle Costs (\$) - 25 years</i>		
Energy	118,282.01	556,945.01
CO2 Emissions	0.00	0.00
Water	0.00	0.00
Maintenance	0.00	0.00
Mechanical Room Lease	0.00	0.00
Installation	0.00	37,740.00
Salvage	0.00	(173.21)
Lifecycle Total	118,282.01	594,511.80

**Annual Energy
Savings**

25 YR Total Example

Objectives: Finance Module

Life Cycle Analysis


Finance Module - 100 ton Example 7 22 09

	Geothermal	Alternate
Energy	5,806.47	21,463.88
CO2 Emissions	622.12	1,073.97
Water	0.00	0.00
Maintenance	532.80	1,776.00
Mechanical Room Lease	0.00	0.00
Annual Total	6,961.39	24,313.85
<i>NPV Lifecycle Costs (\$)-25 years</i>		
Energy	118,282.01	556,945.01
CO2 Emissions	5,981.52	10,325.89
Water	0.00	0.00
Maintenance	8,981.33	29,937.75
Mechanical Room Lease	0.00	0.00
Installation	47,952.00	73,260.00
Salvage	0.00	(173.21)
Lifecycle Total	181,196.85	670,295.44


Full Life Cycle Cost Data

25 YR Total Example


Independent Systems




Central 2-Pipe Constant-Speed




Central 2-Pipe Variable-Speed




Central 1-Pipe Primary/Secondary



Central 1-Pipe Primary/Secondary



Example: Pumping Energy Comparison



Sizing Procedures

Calculate Building / Zone
Heating / Cooling Loads

Select Geothermal Heat Pump/s for
Building / Zones

Design Ground Loop System

Run Operating Costs Comparison Using a
Software Program

Verify Dehumidification in Cooling Mode

Check Effects on Ground Loop System by
Unit Size

Questions?



Thanks for Your Time!